

Change Order Form


State of Ohio Standard Forms and Documents

Project Name and Location Ridgedale Elementary HVAC Upgrade 3105 Hillman Ford Road, Morral Ohio 43337		Contract Number - -		
Contract Type		Modification No.	CO1	- -
Contractor / CM / DB / ESCO Name MG Energy		Description	Electrical Service Underground	
Basis of Change Order		Funding Information		
<input type="checkbox"/> Error / Omission	<input type="checkbox"/> Value Engineering	State Funds		\$0.00
<input type="checkbox"/> Owner Request	<input checked="" type="checkbox"/> Differing Site Condition	Local Funds		\$4,356.00
<input type="checkbox"/> Code Directive	<input type="checkbox"/> Field Resolution	Other Funds (LFI)		\$0.00
<input type="checkbox"/> Other				
Adjustment of the Contract Times		Adjustment to the Contract Sum		
Contract Days Changed	0	Change Order Amount	\$4,356.00	
Revised Completion Date	NA	Revised Contract Sum	\$1,130,872.00	

Description (attach Change Order Summary and Detail forms and additional pages as necessary)
 ore a high voltage underground feeder from the parking lot pole to our pad mounted transformer. Install transformer on existing pole. This minimizes/eliminates future issues with removal of existing well pump and provides pathway to remove existing pole mounted transformers in the future.

Justification (attach additional pages as necessary)
 See reason above

This Change Order provides full and complete satisfaction for all adjustments of the Contract Sum, Contract Times, or both, for the described changes and shall not serve as the basis for a cumulative impact Claim.

Architect/Engineer / Criteria A/E Recommendation Name <u>Ryan Kopko, PE</u>  <u>6/24/22</u> Signature Date		Owner 1 Acceptance Name _____ Signature _____ Date _____	
CM Adviser / Owner Agent Recommendation (if any) Name _____ Signature _____ Date _____		Owner 2 Acceptance (if applicable) Name _____ Signature _____ Date _____	
Contractor / CM at Risk / Design-Builder / ESCO Approval Name _____ Signature _____ Date _____		Contracting Authority Approval Name _____ Signature _____ Date _____	

MG Energy Solutions
 100 West Sixth Street
 Mansfield, Ohio 44902



Office (419) 522-2700
 tgrillo@mg.energy

Change Order

JOB NAME: CO # 01 Ridgedale Elementary CO DATE: June 15, 2022
 JOB LOCATION: Marion, OH CO NUMBER: _____
 CO EXPIRES: _____
 ESTIMATED BY: Paul Hinze
 CUSTOMER: Ridgedale School Board PHONE: _____
 CONTACT: Ryan Kopco FAX: _____
 CUSTOMER SIGNATURE: _____ DATE: _____

QTY	DESCRIPTION	UNIT PRICE	TOTAL
1.00	Mark Danals of Spring Electric has requested a change order for the following	\$4,356.00	\$4,356.00
	The School has a concern about the pole and overhead wiring being unsafe and difficult to pull the well pump. Gary Vanderhoff (Mid-Ohio Energy) suggestion is to add cut outs to the parking lot pole, upstream from the transformer pole. Then bore a high voltage underground feeder from the parking lot pole to our pad mounted transformer.		\$0.00
			\$0.00
			\$0.00
			\$0.00
			\$0.00
			\$0.00
			\$0.00

Comments: _____

SUBTOTAL	\$4,356.00
SALES TAX	\$0.00
SHIPPING & HANDLING	\$0.00
OTHER	\$0.00
TOTAL	\$4,356.00

High Efficiency HVAC Systems - Professional Engineering - Boiler & Chiller Systems

Design/Build Turnkey Projects - Building Automation - Domestic Hot Water Systems - 24/7 Service and Repairs